



Tested with double 2" x 6"  
(pressure treated spruce)  
Installed side by side

**GENERAL NOTES:**

- 1) THE LOAD RESISTANCE OF THE GLASS AND SPIGOT COMPONENTS INSTALLED IN THE CONFIGURATIONS AS SHOWN MEET THE LOAD REQUIREMENTS SPECIFIED IN SECTIONS 9.8.8.2 AND 4.1.5.14.1 (c) OF THE 2015 NBC AND THE 2012 OBC.
- 2) GLASS THICKNESS IS 1/2" OR 12 MM, AND MUST BE TEMPERED OR LAMINATED SAFETY GLASS INSTALLED IN ACCORDANCE WITH THE REQUIREMENTS OF CAN/CGSB-12.1-M.
- 3) CERTIFICATION IS FOR GUARD COMPONENTS ONLY. FASTENING THE SPIGOT TO THE SUPPORT STRUCTURE IS A SITE CONDITION AND THE INSTALLERS MUST ENSURE THAT THE FASTENERS ARE ADEQUATE TO RESIST THE DESIGN LOADS.
- 4) THE MATERIAL TO WHICH THE GLASS SUPPORTS ARE BEING FASTENED MUST ADEQUATELY RESIST THE DESIGN LOADS.

**Fasteners used for testing:**

- On concrete:**
- Wedge anchor M12 x 4"
- On wood:**
- M12 hanger bolt with min. 3" of thread embedded in wood
  - Optional: M12 threaded rod with flat washers and nuts

Glass panel height: Max. 48"  
W (Glass width): Min. 26"  
A = Max. 36"  
B = Min. 6" and Max. 9"

**Common sizes:**

| W (in) | A (in) | B (in) | Number of spigots |
|--------|--------|--------|-------------------|
| 72     | 27     | 9      | 3                 |
| 60     | 22     | 8      | 3                 |
| 48     | 32     | 8      | 2                 |
| 36     | 22     | 7      | 2                 |
| 26     | 14     | 6      | 2                 |



| FINISH | CODE         |
|--------|--------------|
| Satin  | SSSPIGOTSIDE |

**euro**  
ARCHITECTURAL  
COMPONENTS  
127A Aviva Park Dr., Woodbridge, ON, CANADA  
www.euroeac.com | Toll Free: 1-800-465-7143

|           |                |
|-----------|----------------|
| MATERIAL: | SS Duplex 2205 |
| WEIGHT:   | -----          |
| SCALE:    | As Noted       |
| DRAWN:    | A.R            |
| DATE:     | 04/26/2017     |

| TITLE                                | DWG NO           |
|--------------------------------------|------------------|
| Side Mount Spigot<br>Tilt Adjustable | SSSPIGOTSIDE-ENG |

|                 |
|-----------------|
| SHEET<br>1 of 1 |
| REV<br>02       |